

Test Object : Current Instrument Transformer

Type : CTS 38 X Sch

Ratings:

Design: cast resin insulated for indoor use			
Serial number:		024274 / 2005	024275 / 2005
Rated primary current	[A]	300	5
Rated secondary current	[A]	5 / 5	5
Highest system voltage	[kV]	38,5	38,5
Power frequency withstand voltage	[kV]	80	80
Lightning-impulse withstand voltage	[kV]	180	180
Rated output	[VA]	15 / 15	10
Accuracy class		0,5 / 0,5	0,2S
Rated short - time thermal current	[kA]	31,5	2
Rated dynamic current	[kA]	65	5
Rated frequency	[Hz]	50	50
FS / ALF		5/5 // --	5 / --

Manufacturer: KPB Intra s.r.o, BUČOVICE

Test performed : Dielectric tests according to requirements of customer:
Lightning impulse test on primary winding
Power - frequency withstand test on primary windings

Test specification : ČSN EN 60044 – 1 (2001), IEC 60044 – 1 (1997), ČSN 333201 (2002)
GOST1516.3-96, KPB Intra s.r.o, order Nr. 003000366/2005

Test results : The transformers CTS 38 X Sch, serial number 024274 / 2005 and 024275 / 2005, have been tested in accordance with IEC 60044-1, ČSN EN 60044 – 1 (2001), ČSN 333201 (2002) and GOST1516.3-96.
Transformers are considered to comply with the above standards.

Date of test : 7. 10. 2005

12. 10. 2005

Date of issue

Test manager



Laboratory manager

This test concern exclusively to the object tested. This test report is issued by Technical Laboratory that is member of CTLA (Association of Czech Testing Rooms and Laboratories) with right to use cancellation No. 028. The report shall not be reproduced except in full without the written approval of the Technical Laboratory
ABB s.r.o. Unit EJF: Technical laboratory Vídeňská 117 CZ 619 00 Brno Fax : +420 5 4715 2302 Phone: +420 57152365

Headquarters:
ABB s.r.o.
Sokolovská 84-86
186 00 Prague 8
Czech Republic

Mail Address:
ABB s.r.o.
Videnska 117
619 00 Brno
Czech Republic

Phone: + 420 5 4715 2469
Fax: + 420 5 4715 2950





- The transformers **CTS 38 X Sch**, serial number 024274 / 2005 and 024275 / 2005 have been subjected to the following dielectric tests and measurement::

TEST PROGRAM:

standard

- | | |
|--|---|
| 1. Verification of terminal markings | ČSN EN 60044-1, cl. 8.1
GOST1516.3-96
IEC 60044-1, cl. 8.1, ČSN 333201 |
| 2. Lightning- impulse test | ČSN EN 60044-1, cl. 7.3
GOST1516.3-96, čl. 7
IEC 60044-1, cl. 7.3, ČSN 333201 |
| 3. Power - frequency withstand test on primary windings | ČSN EN 60044-1, cl. 8.2
GOST1516.3-96, čl.7
IEC 60044-1, cl. 8.2, ČSN 333201 |

Results of tests performed on transformer CTS 38 X Sch:

Serial No.: 024274 / 2005

page 3

Serial No.: 024275 / 2005

page 4

All tests and measurement have been performed in Technical laboratory ABB s.r.o EJF, Brno.

Ambient air conditions during tests: Temperature: 21,4° C
Rel. humidity: 44,3%
Pressure: 1012 hPa

Devices and equipment used:

Test transformer 100 kV Nr. 93425
Measuring system TETTEX type 9124 Nr. 136810
Impulse generator TUR Dresden Nr. 94272
Digital Impulse Voltage Measuring System TR – AS 25-8 , Dr.STRAUSS

List of symbols used::

I_p	Rated primary current	[A]
I_s	Rated secondary current	[A]
P	Rated output	[VA]
U_m	Highest system voltage	[kV]
f	Rated frequency	[Hz]
I_{th}	Rated short - time thermal current	[kA]
I_{dyn}	Rated dynamic current	[kA]
U_{zk}	Test voltage	[kV]



Technical Laboratory

TEST REPORT No. 1VLR 016445

Page 3 of 4

issued by Technical laboratory in accordance with EN 17025

Standard: ČSN EN 60044 – 1 (2001), IEC 60044 – 1 (1997), ČSN 333201 (2002), GOST1516.3-96					
TYPE :		CTS 38 X Sch		Serial No. : 024274/2005	
RATINGS :					
I _p [A]	300	I _s [A]	5 / 5	P [VA]	15 / 15
Accuracy	0,5 / 0,5	FS	5 / 5	ALF	--
U _m / U _{zk} [kV]	38,5 / 80 / 180	f [Hz]	50	I _{th} / I _{dvn} [kA]	31,5 / 65

1. Verification of terminal markings:

- It was verified that the terminal markings are correct and in accordance with drawings.

2. Lightning - impulse test:

- Test voltage applied between short-circuited primary winding and earth. The short-circuited secondary windings and the frame connected to earth.
- Voltage form was in accordance with IEC 60060-1

Test voltage	impulses	flashovers	Result:
+ 180 kV	15	0	has passed
- 180 kV	15	0	has passed
Test voltage	impulses	flashovers	Result:
+ 190 kV	15	0	has passed
- 190 kV	15	0	has passed

3. Power-frequency withstand test on primary windings:

- Test voltage applied between short-circuited primary winding and earth. The short-circuited secondary windings and the frame connected to earth:

Test voltage	frequency	test duration	Result:
80 kV	50 Hz	60 sec.	has passed



Technical Laboratory

TEST REPORT No. 1VLR 016445

Page 4 of 4

issued by Technical laboratory in accordance with EN 17025

Standard: ČSN EN 60044 – 1 (2001), IEC 60044 – 1 (1997), ČSN 333201 (2002), GOST1516.3-96					
TYPE :		CTS 38X Sch		Serial No. : 024275/2005	
RATINGS :					
I_p [A]	5	I_s [A]	5	P [VA]	10
Accuracy	0,2S	FS	5	ALF	--
U_m/ U_{zk} [kV]	38,5 / 80 / 180	f [Hz]	50	I_{th} / I_{dvn} [kA]	2 / 5

1. Verification of terminal markings:

- It was verified that the terminal markings are correct and in accordance with drawings.

2. Lightning - impulse test:

- Test voltage applied between short-circuited primary winding and earth. The short-circuited secondary windings and the frame connected to earth.
- Voltage form was in accordance with IEC 60060-1

Test voltage	impulses	flashovers	Result:
+ 180 kV	15	0	has passed
– 180 kV	15	0	has passed
Test voltage	impulses	flashovers	Result:
+ 190 kV	15	0	has passed
– 190 kV	15	0	has passed

3. Power-frequency withstand test on primary windings:

- Test voltage applied between short-circuited primary winding and earth. The short-circuited secondary windings and the frame connected to earth:

Test voltage	frequency	test duration	Result:
80 kV	50 Hz	60 sec.	has passed