




Electrotechnical Engineering and Production, joint-stock company
619 00 BRNO, Vídeňská 117

REPORT OF PERFORMANCE No: 88-0158

INSTRUMENT VOLTAGE TRANSFORMERS TYPE VTS 12




Jaromír Mudra, Phd

Brno, July 9 1998

Warning: Publication of the contents of this report is not permitted without agreement of the person who has ordered the test.
The report can be reproduced only as a whole and with the written agreement of the testing laboratory.



TEST REPORT No: 88 - 0158
Tested Instrument Voltage
subject: Transformers

Page No.: 2

Number of
pages: 7

TYPE:

VTS 12 2 pieces

KIND OF TEST: partial test

TESTING ACC. TO:

IEC 186, Clause 12
(Short-circuit withstand
capability test)

RATED VALUES:

Rated transformer ratio

10/√3//0.1/√3//0.1/3 kV

6/√3// 0.1/√3V //0.1/3 kV

TEST REQUEST ISSUED BY:

KBP INTRA s.r.o.
Fučíkova 860
685 01 Bučovice

ORDER NUMBER:

Z-98002 of Feb. 17, 1998

TESTED SPECIMEN REG. NUMBER:

076/98 and 184/98

ENVIRONMENTAL CONDITIONS:

TEMPERATURE: 23°C
ATMOSPHERIC PRESSURE:
AIR HUMIDITY:

PRODUCT MANUFACTURER

KPB Intra, s.r.o.
Fučíkova 860
685 01 Bučovice

**THIS TEST REPORT
INCLUDES:**

TEXT PAGES: 7
TABLES: 4
OSCILLOGRAMMES:
DIAGRAMMES:
DRAWINGS:
PHOTOS:

**DISTRIBUTION
LIST:**

Client 2x
IVEP Brno
Archives 1x
ŘZ 1x
ŘT 1x

TESTED SPECIMENS DELIVERED ON:

Feb. 10, 1998

TEST RESULT:

All the instrument voltage transformers under test did

c o m p l y

with the short-circuit withstand capability requirements to
IEC 186, Art. 12.

DATE OF TEST:

June 8 to 9,
1998

TEST PERFORMED BY:

Mr. Petr Kalus

TEST LAB

Mudra, PhD.



	TEST REPORT No. : 88-0158	page: 3
	Tested subject: Instrument Voltage Transformer	number of pages: 7

1 Tests required and the respective parameters

T y p e	T e s t	U_z [kV]	cos [1]	t_k [s]	winding
VTS 12	Short-circuit with-stand capability	6.4	0.9	1	a- n da-dn
VTS 12	Short-circuit with-stand capability	3.7	0.9	1	a- n da-dn


2 Tested specimen identification

a) Instrument voltage transformer, reg. No. 076/98 :

Type : VTS 12
 U_{n1} : $10/\sqrt{3}$ kV
 U_{n2} : $100/\sqrt{3}$ // 100/3 V
 f_n : 50 Hz
accuracy class : 0.5 - 50 VA
 3 P - 100 VA
quantity : 1 pc
production number : 1200004

b) Instrument voltage transformer, reg. No. 184/98 :

Type : VTS 12
 U_{n1} : $6/\sqrt{3}$ kV
 U_{n2} : $100/\sqrt{3}$ // 100/3 V
 f_n : 50 Hz
accuracy class : 0.5 - 50 VA
 6 P - 100 VA
quantity : 1 pc
production number : 1200002



	TEST REPORT No. : 88-0158	page: 5
	Tested subject: Instrument Voltage Transformer	number of pages: 7

4 Measuring instruments and symbols used

WH	- Outdoor, power supply line No. 165; 22 kV;
QM	- Protective SF6 circuit-breaker; VF 251225; 25 kV; 1 250 A; p=0.5 MPa; EJF Brno;
TM3	- KobU 825/20 Testing transformer; 1.25 MVA; 22//12.7/11/7.34/6.35/3.67 kV; D//y/d; $u_k=1,8/2.31\%$; BEZ Bratislava;
R1, L1	- Medium voltage burdens at the short-circuit station;
R2	- 0.01 Ω burden of tested transformer;
TV1	- Instrument voltage transformer; D225; 22000/100 V; EJF;
TA1	- Instrument current transformer; PE225; 200/5 A; EJF;
TV2	- Tested instrument voltage transformer;
RB1	- Shunt 3.344 A/V; IVEP Brno;
UF1-3	- FM 10 Analogous, opto-electronic measuring system; (V=transmitter, P=receiver); VÚSE Běchovice;
PH2	- PCL 818 Data recording card;
KO	- Cathode oscillogram;
ZO	- Testing operation;
T	- Test by temperature current;
u_1	- Instantaneous value on transformer primary terminals
u_k	- Transformer short-circuit voltage, in percent;
U_{n1}	- Transformer rated primary voltage;
U_{n2}	- Transformer rated secondary voltage;
U_1	- Rms voltage value on transformer primary terminals;
U_2	- Rms current value of line testing voltage;
i_1	- Instantaneous value of current through the primary winding;
i_2	- Instantaneous value of current through the secondary winding;
I_1	- Rms value of current flowing through the primary winding;
I_2	- Rms value of current flowing through the secondary winding;
t_k	- Short-circuit time period; time period of current pass-through;
$\cos \varphi$	- Testing circuit power factor;

	TEST REPORT No. : 88-0158	page: 6
	Tested subject: Instrument Voltage Transformer	number of pages: 7

5 Sequence and progress of the test

The sequence of tests carried through results from the table shown in chapter 6. Power into the instrument voltage transformers was fed into the primary winding, with always one secondary winding connected to a burden of 0.01Ω for monitoring the waveform of secondary current. The short-circuit time period was 1 second. In all the testing operations the waveforms of primary and secondary currents was picked-up by the PCL 818 data registration card.

All the registered cathode oscillogrammes, being a part of this test report, are documented and archived.

6 Table of measured values

$$\cos \varphi = 0.9$$

Speci- men	ZO	KO	short-circui- ted winding (terminals)	U_1 [kV]	I_1 [A]	I_2 [A]	t_k [s]	Note
076/98	T	982301	a - n	6.4	1.2	124	1.01	
	T	982302	da - dn	6.4	0.6	133	1.01	
184/98	T	982303	a - n	3.7	1.4	147	1.01	
	T	982304	da - dn	3.7	0.4	68	1.01	

	TEST REPORT No. : 88-0158	page: 7
	Tested subject: Instrument Voltage Transformer	number of pages: 7

7 Test results

7.1 Short-circuit withstand capability test on the specimen No. 076/98 :

The tested instrument voltage transformer did **c o m p l y** with the testing requirements to IEC 186, Clause 9.7 and 12, when connected in a power testing circuit with the following parameters:

a) short-circuited "a - n" windindg

$U_z = 6.4 \text{ kV}$; $I_1 = 1.2 \text{ A}$; $I_2 = 124 \text{ A}$; $\cos = 0.9$; $t_k = 1.01 \text{ s}$.

b) short-circuited "da - dn" winding

$U_z = 6.4 \text{ kV}$; $I_1 = 0.6 \text{ A}$; $I_2 = 133 \text{ A}$; $\cos = 0.9$; $t_k = 1.01 \text{ s}$.

7.2 Short-circuit withstand capability test on the specimen No. 184/98 :

The tested instrument voltage transformer did **c o m p l y** with the testing requirements to IEC 186, Clause 9.7 and 12, in a power testing circuit with the following parameters:

a) short-circuited "a - n" winding

$U_z = 3.7 \text{ kV}$; $I_1 = 1.4 \text{ A}$; $I_2 = 147 \text{ A}$; $\cos = 0.9$; $t_k = 1.01 \text{ s}$.

b) short-circuited "da - dn" winding

$U_z = 3.7 \text{ kV}$; $I_1 = 0.4 \text{ A}$; $I_2 = 68 \text{ A}$; $\cos = 0.9$; $t_k = 1.01 \text{ s}$.

After finishing the test the tested transformers did not exhibit any visual damage and complied with all the repeated testing requirements.

8 Persons taking part in the test

IVEP Brno, a. s.:

Mr. Petr Kalus
Mr. Vlastimil Rada

